



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

June 2, 2014

ADDENDUM NUMBER TWO

RFQ # 7548705

TITLE: Hot Water Heater Replacement at Regan Building

Closing Date and Time: 6/9/14 at 1:30pm (note change)

Per the issuance of this ADDENDUM #2 (1 page) the following is noted:

The closing date and time has been changed from:

6/3/14 at 11AM

To

6/9/14 at 1:30PM

See clarification of specification below (revisions in bold and underlined):

The storage tank specification shall be revised as follows:

The storage tanks shall be A.O. Smith model custom line insulated and jacketed vertical storage tanks with supports or approved equal. Tank capacity shall be a total of 1,800 gallons and shall be in the vertical orientation. It shall be built to the ASME Code, "U" stamped and registered with the National Board of Pressure Vessel Inspectors. Minimum ASME working pressure 125 PSI. Vertical tanks shall be provided with legs with drilled foot pads.

Tanks shall be furnished complete with opening for a temperature-pressure relief valve, temperature-pressure gauge, and necessary openings for circulating lines, cold water inlet, hot water outlet, gauge, inspection(s), and drain.

Minimum size 4" x 6" inspection port must be provided. **Provide a manhole a minimum size of 11"x15"**. The storage vessel **shall be cement lined**. Insulation shall exceed ASHRAE 90.1 standards for thermal efficiency and standby loss. The exterior of the tank jacket shall be finished with an attractive enamel heat resistant finish.

Tank Warranty- tank shall carry a **minimum 5 year** manufacturer's warranty against leakage.